

Certificate of Product Approval

Certificate Number: 566e

Issue: 04

Rapidrop Global Limited

Rutland Business Park
Newark Road
Peterborough
PE1 5WA
United Kingdom



is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Model RD Sprinklers

(refer to attached appendix for details)

Standards

EN 12259-1:1999 including amendment +A3:2006

Fixed firefighting systems. Components for sprinkler and water spray systems. Sprinklers

This certificate and appendix is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

S. A. Colwell

Signed for BRE Global Ltd.

Sarah Colwell

Verifier

13 October 2017

Date of Issue

9 February 2010

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 566e Rapidrop Global Limited

Issue: 04

Model RD Sprinklers

Product Name	Nominal orifice size (mm)	Type	Temperature rating (°C)	LPCB Ref. No.
Rapidrop RD101 (1)(2)(4)	15	SLP	72, 96 (quick response)	566e/01
Rapidrop RD102 (3)(4)	15	SLP	72, (quick response)	566e/02

Notes:

- (1) Approved with plain, chrome and coloured finish
- (2) This sprinkler must be handled with care, and the protective cap which protects the thermal element should only be removed after installation is completed. To be installed in accordance with Data Sheet 4.12.
- (3) These sprinklers are approved with a painted white (other RAL colours available on request) or a chrome finished escutcheon, and must be installed in accordance with Rapidrop Data Sheet 4.27.
- (4) These sprinklers are approved for use with the Lumi Plugin LP120 fitted co-axially with the sprinkler. Their installation must comply with Rapidrop product Data Sheet 14.01, issue A, Sept. 2017.

This certificate and appendix is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

S.A.C. Colwell

Signed for BRE Global Ltd.

Sarah Colwell

Verifier

13 October 2017

Date of Issue

9 February 2010

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX

T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre