



Sprinkler System Components | Indicator Posts | **Indicator Posts**

## Fig 101L

Fig 101L. Vertical type.

Note: Fig 101L indicator posts are Approved for use with 14 through 24 inch NPS non-rising stem gate valves with an indicator post flange.

### Details

**Class of Work** : 1110 - Indicator Posts

**Approval Standard** : FM 1110 - Indicator Posts

**Certification Type** : FM Approved

**Listing Country** : United Kingdom

**Category** : Indicator Posts

### Company

**Rapidrop Global Limited**

Rutland Business Park, Newark Rd, Peterborough

PE1 5WA, United Kingdom

United Kingdom

**<http://www.rapidrop.com>**