

Sprinklers, Automatic and Open

COMPANY

RAPIDROP GLOBAL LTD

RUTLAND BUSINESS PARK
 NEWARK RD
 PETERBOROUGH, PE1 5WA United Kingdom

EX15182

Sprinkler Identification Number (SIN), Glass Bulb Type RD001, RD009, RD010, RD022, RD023, RD024, RD025, RD026, RD027, RD042, RD043, RD044, RD045, RD052, RD053, RD054, RD055, RD060 and RD061.

**UPRIGHT AND PENDENT STANDARD SPRAY SPRINKLERS
 NOMINAL 5.6 K-FACTOR**

SIN	Response Type	Type	System Working Pressure, psig	Temp Rating, °F
RD022	SR	Pendent	175	135, 155, 175, 200, 286
RD023	QR	Pendent	175	135, 155, 175, 200, 286
RD024	SR	Upright	175	135, 155, 175, 200, 286
RD025	QR	Upright	175	135, 155, 175, 200, 286
RD026	SR	Upright	175	135, 155, 175, 200, 286
RD027	QR	Upright	175	135, 155, 175, 200, 286

* - Installed 4 to 6 in. below ceiling.

NOMINAL 8.0 K-FACTOR

SIN	Response Type	Type	Inlet Thread NPT	System Working Pressure, psig	Temp Rating, °F
RD042	SR	Pendent	3/4	175	135, 155, 175, 200, 286
RD043	QR	Pendent	3/4	175	135, 155, 175, 200, 286
RD044	SR	Upright	3/4	175	135, 155, 175, 200, 286
RD045	QR	Upright	3/4	175	135, 155, 175, 200, 286
RD052	SR	Pendent	1/2	175	135, 155, 175, 200, 286
RD053	QR	Pendent	1/2	175	135, 155, 175, 200, 286
RD054	SR	Upright	1/2	175	135, 155, 175, 200, 286
RD055	QR	Upright	1/2	175	135, 155, 175, 200, 286

Feedback

STANDARD SIDEWALL SPRAY SPRINKLERS

SIN	Response Type	Type	Nom K-Factor	System Working Pressure, psig	Temp Rating, °F
RD060+#	SR	Horizontal	5.6	175	135, 155, 175, 200, 286
RD061+#	QR	Horizontal	5.6	175	135, 155, 175, 200, 286

+Installed 4 to 12 in. below ceiling.

- For ordinary hazard occupancies.

FLUSH, RECESSED, AND CONCEALED SPRINKLERS

SIN	Response Type	Type	Nom K-Factor	Cover	Temp. Rating, °F
RD009	SR	Concealed	5.6	135	155
RD010	QR	Concealed	5.6	135, 155	155, 200
RD105	QR	Concealed	5.6	140(60), 162(72)	162(72), 205(96)
RD103	QR	Flush Pendent	5.6	—	162, 205

FLUSH, RECESSED AND CONCEALED SPRINKLERS

Model	Response Type	Type	Orifice Size In.	Temp Rating F (C)	
				Cover	Sprinkler
RD106	QR	Concealed	5.6	140(60), 162(72)	162(72), 205(96)

Trademark and/or Tradename:  , "Rapidrop"

Last Updated on 2023-08-24

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2023 UL LLC."